

WTC 499.18
DRAWING NUMBER
E-25
5/16/90

DRAWING NUMBER

DRAWING NUMBER

SMOKE DETECTION PANEL XL No. 10 SCHEDULE 'B' (DUAL ADDRESS INPUTS)						
INPUT			OUTPUT			REMARKS
ADDRESS No. 1	ADDRESS No. 2	INITIATING DEVICES	RESULTING ADDRESS	ANNUNCIATOR MESSAGES	ACTIVATED RELAYS	
101104	101105	POX-31-131 INTERFACE MODULE TRX-2R-6-7	101130	SOL VALVE DUMP 75 EAST TWR 2	SPX-14-023 GROUP A	SOL. VALVE DUMP ACS-75-3 GROUP A
101104	101106				SPX-17-051 GROUP A	SOL. VALVE DUMP ACS-75-12 GROUP A
101107	101108				SPX-16-041 GROUP A	SOL. VALVE DUMP ACS-75-8 GROUP A
101109	101110				SPX-14-022 GROUP A	SOL. VALVE DUMP ACS-75-2 GROUP A
101201	101202				SPX-16-044 GROUP A	SOL. VALVE DUMP ACS-75-11 GROUP A
101201	101203				SPX-15-034 GROUP A	SOL. VALVE DUMP ACS-75-7 GROUP A
101204	101205				SPX-17-053 GROUP A	SOL. VALVE DUMP ACS-75-14 GROUP A
101206	101207				SPX-18-061 GROUP A	SOL. VALVE DUMP ACS-75-16 GROUP A
101208	101209				GROUP A POX-25-073 RETURN AIR FAN ACR-75-7 SHUTDOWN POX-25-074 RETURN AIR FAN ACR-75-8 POX-26-081 RETURN AIR FAN ACR-75-9 POX-26-082 RETURN AIR FAN ACR-75-10 POX-26-083 RETURN AIR FAN ACR-75-11 POX-26-084 RETURN AIR FAN ACR-75-12 POX-19-013 SUPPLY FAN ACS-75-2 POX-19-014 SUPPLY FAN ACS-75-3 POX-20-024 SUPPLY FAN ACS-75-7 POX-21-031 SUPPLY FAN ACS-75-8 POX-21-032 SUPPLY FAN ACS-75-11 POX-22-041 SUPPLY FAN ACS-75-12 POX-22-043 SUPPLY FAN ACS-75-14 POX-23-051 SUPPLY FAN ACS-75-16	
101210	101211					
101111	101112	POX-31-133 INTERFACE MODULE TRX-2R-6-9	101129	SOL VALVE ACS-75-17 TWR 1	SPX-18-062	SOL. VALVE DUMP ACS-75-17

SMOKE DETECTION PANEL XL No. 10 SCHEDULE 'B' (DUAL ADDRESS INPUTS)						
INPUT			OUTPUT			REMARKS
ADDRESS No. 1	ADDRESS No. 2	INITIATING DEVICES	RESULTING ADDRESS	ANNUNCIATOR MESSAGES	ACTIVATED RELAYS	
101301	101302	POX-31-132 INTERFACE MODULE TRX-2R-6-8	101330	SOL VALVE DUMP 75 WEST TWR 2	SPX-17-054 GROUP B	SOL. VALVE DUMP ACS-75-15 GROUP B
101303	101304				SPX-17-052 GROUP B	SOL. VALVE DUMP ACS-75-13 GROUP B
101305	101306				SPX-15-032 GROUP B	SOL. VALVE DUMP ACS-75-5 GROUP B
101307	101308				SPX-16-042 GROUP B	SOL. VALVE DUMP ACS-75-9 GROUP B
101309	101310				SPX-15-031 GROUP B	SOL. VALVE DUMP ACS-75-4 GROUP B
101309	101311				SPX-16-043 GROUP B	SOL. VALVE DUMP ACS-75-10 GROUP B
101401	101402				SPX-15-033 GROUP B	SOL. VALVE DUMP ACS-75-6 GROUP B
101403	101404				SPX-14-021 GROUP B	SOL. VALVE DUMP ACS-75-1 GROUP B
101405	101406				GROUP B POX-24-061 RETURN AIR FAN ACR-75-1 SHUTDOWN POX-24-062 RETURN AIR FAN ACR-75-2 POX-24-063 RETURN AIR FAN ACR-75-3 POX-24-064 RETURN AIR FAN ACR-75-4 POX-25-071 RETURN AIR FAN ACR-75-5 POX-25-072 RETURN AIR FAN ACR-75-6 POX-19-012 SUPPLY FAN ACS-75-1 POX-20-021 SUPPLY FAN ACS-75-4 POX-20-022 SUPPLY FAN ACS-75-5 POX-20-023 SUPPLY FAN ACS-75-6 POX-21-032 SUPPLY FAN ACS-75-9 POX-21-033 SUPPLY FAN ACS-75-10 POX-22-042 SUPPLY FAN ACS-75-13 POX-22-044 SUPPLY FAN ACS-75-15	
101405	101407					



THE PORT AUTHORITY
OF NY & NJ

James Carley
ENGINEER OF DESIGN E.D.D., PORTS AND
WORLD TRADE
James A. Ball
CHIEF ELECTRICAL ENGINEER

Engineering Department
Design Divisions

World
Trade
Center

Title
TOWER M.E.R'S
SPRINKLER INSTALLATION
AND MODIFICATION
TO SMOKE DETECTION
SYSTEM
ELECTRICAL
SMOKE DETECTION PANEL
XL No. 10 ANNUNCIATOR
MESSAGE AND
SHUTDOWN SCHEDULE
SHEET 2 OF 2

No. Date Revision Approved

This drawing subject to conditions in contract.
All inventions, ideas, designs and methods
herein are reserved to Port Authority and
may not be used without its written consent.

DESIGNED BY
AVENOSO
AVENOSO
PALANGO
Designed by Drawn by Task Leader

Checked by *1-10-90*

Date 5-16-90 Scale NONE

Contract Number
WTC 499.18
Drawing Number
E-25

MAY 15, 1990
FILE NAME: 4591825